



## RAPORT DE ÎNCERCARE

nr. / Data emiterii : pt0163970 / 11-04-2016

Nume / adresa client : **STANCU BEBE / Sos. Alexandria nr. 2, Bragadiru, Ilfov**  
 Provenienta probei : **proba apa Bragadiru (recoltata de client)**  
 Data primirii probei / data efectuării analizelor : **07-04-2016 / 07-04-2016 - 09-04-2016**

Indicatori organoleptici si fizico-chimici	Unitate de masura	Valori obtinute	Incertitudine de masurare la CMA	Valori maxime admise (conf. L.458/2002 cons. in 2015)	Referential
Miros*	-	Acceptabila	-	Acceptabila consumatorilor si nici o modificare anormala	SR EN 1622 /2007
Gust*	-	-	-	Acceptabila consumatorilor si nici o modificare anormala	SR EN 1622 /2007
Culoare*	grade	1	-	Acceptabila consumatorilor si nici o modificare anormala	SR EN ISO 7887/2012
Turbiditate	UNT	0,283	±5%	≤ 5	SR EN ISO 7027/2001
pH	unitati pH	7,95 / 20,7 °C	±3%	≥6,5 ; ≤9,5	SR EN ISO 10523/2012
Conductivitate	µS/cm la 25° C	460	±5%	2500	SR EN 27888/1997
Clor rezidual liber	mg/l	<0,06	±10%	≥ 0,1 - ≤ 0,5	SR EN ISO 7393-2/2002
Amoniu	mg/l	2,329	±5%	0,50	SR ISO 7150-1/2001
Nitriti	mg/l	0,235	±7%	0,50	SR EN 26777/ C91/2006
Nitrati	mg/l	0,171	±6%	50	SR ISO 7890-3/2000
Fier total	µg/l	47	±7%	200	SR ISO 6332/1996/C91/2006
Oxidabilitate	mgO2/l	1,76	±16%	5,0	SR EN ISO 8467/2001
Duritate totala	grade germane	2,75	±4%	25	SR ISO 6059/2008
Aluminiu	µg/l	<8	±9%	200	SR ISO 10586/2001

Rezultatele incercarilor se refera numai la proba de apa analizata. Proba de apa are caracter momentan.

Proba se preleveaza conform procedurii operationale cod : LCCAP PO 007

Raportul de incercare se completeaza in doua exemplare.

\* Incercare nerecruizata

Document proprietatea S.C.APA NOVA S.A. - reproducerea partiala este interzisa fara acordul laboratorului.

Cod LCCAP - F17.01 Rev. 2003.2015

Rezultatele notate "c" reprezinta valori situate sub limita de cuantificare a metodei. CMA: concentratia maxim admisa

Indicatori bacteriologici / UM / Referential	Valori obtinute	Valori admise (conf. L.458/2002 cons. in 2015)
Bacterii coliforme (UFC/100 ml)	0	0
SR EN ISO 9308-1:2015		
Escherichia coli (UFC/100 ml)	0	0
SR EN ISO 9308-1:2015		
Enterococi (UFC/100 ml)	0	0
SR EN ISO 7899 - 2 : 2002		

Funcție	Nume, prenume	Semnatura
Intocmit / Ing. chimist	Ramiresi Nicoleta	<i>[Signature]</i>
Intocmit biologic	Mandache Mihaela	<i>[Signature]</i>
Verficat/Aprobat/ Sel laborator	Liescu Mariana	<i>[Signature]</i>

APA NOVA S.C. APA NOVA BUCUREȘTI S.A.  
 Laborator Control  
 Calitatea Apei Potabile